



OPTIONAL ANNUAL REPORT TEMPLATE

<b>Drinking-Water System Number:</b>	220001520
<b>Drinking-Water System Name:</b>	SOUTH HURON DISTRIBUTION SYSTEM
<b>Drinking-Water System Owner:</b>	MUNICIPALITY OF SOUTH HURON
<b>Drinking-Water System Category:</b>	LARGE RESIDENTIAL
<b>Period being reported:</b>	2021/01/01 – 2021/12/31

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [ X ]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [ X ] No [ ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <table border="1" style="width: 100%;"> <tr> <td>OFFICE INTERNET LIBRARY</td> </tr> </table>	OFFICE INTERNET LIBRARY	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ ] No [ ]</p> <p>Number of Interested Authorities you report to: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ ]</p>
OFFICE INTERNET LIBRARY		

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?  
Yes [ ] No [ ] NA [X ]



Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method (Social Media, Facebook, Twitter)\_\_\_\_\_

**Describe your Drinking-Water System**

**LARGE MUNICIPAL RESIDENTIAL DISTRIBUTION CLASS III SURFACE WATER SUPPLIED FROM LAKE HURON PRIMARY WATER SUPPLY SYSTEM (LHPWSS)**

**List all water treatment chemicals used over this reporting period**

**CHLORINE**

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**Please provide a brief description and a breakdown of monetary expenses incurred**

1. Hwy 21 Control Chamber - \$ 377,710
2. Gravelle, Eva , Kingsmere Watermain replacements - \$ 343,404
3. Sunnyside and Maple Grove Watermain Replacements - \$ 289,115
4. Mac Naughton Reservoir re-chlorination system - \$ 406,740
5. Engineering for Blackbush line Watermain replacement - \$25,000
6. Engineering for Huron St East atermain replacement - \$ 25,000
7. Replacement utility dump trailer - \$ 12,000
8. New free chlorine analyzer - \$ 8,000

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
Jan 19/21	Total Coliform	1	cfu/100 ml	Resample	Jan 21/21



--	--	--	--	--	--

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	N/A				
Treated	N/A				
Distribution	524	0	0-1	158	< 10 – 740

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**

	Number of Grab Samples	Range of Results (min #)-(max #)	Unit of Measure
Turbidity	N/A		
Chlorine	8760	0.29 – 2.69	MG/L FREE
Fluoride (If the DWS provides fluoridation)	N/A		

*NOTE: For continuous monitors use 8760 as the number of samples.*

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony				
Arsenic				
Barium				
Boron				
Cadmium				
Chromium				
*Lead				
Mercury				
Selenium				



<b>Sodium</b>				
<b>Uranium</b>				
<b>Fluoride</b>				
<b>Nitrite</b>				
<b>Nitrate</b>				

\*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

**Summary of lead testing under Schedule 15.1 during this reporting period**

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

<b>Location Type</b>	<b>Number of Samples</b>	<b>Range of Lead Results (min#) – (max #)</b>	<b>Unit of Measure</b>	<b>Number of Exceedances</b>
<b>Plumbing</b>			<b>ug/L</b>	
<b>Distribution</b>			<b>ug/L</b>	

**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

<b>Parameter</b>	<b>Sample Date</b>	<b>Result Value</b>	<b>Unit of Measure</b>	<b>Exceedance</b>
<b>Alachlor</b>				
<b>Aldicarb</b>				
<b>Aldrin + Dieldrin</b>				
<b>Atrazine + N-dealkylated metabolites</b>				
<b>Azinphos-methyl</b>				
<b>Bendiocarb</b>				
<b>Benzene</b>				
<b>Benzo(a)pyrene</b>				
<b>Bromoxynil</b>				
<b>Carbaryl</b>				
<b>Carbofuran</b>				
<b>Carbon Tetrachloride</b>				
<b>Chlordane (Total)</b>				
<b>Chlorpyrifos</b>				
<b>Cyanazine</b>				
<b>Diazinon</b>				
<b>Dicamba</b>				
<b>1,2-Dichlorobenzene</b>				
<b>1,4-Dichlorobenzene</b>				
<b>Dichlorodiphenyltrichloroethane (DDT) + metabolites</b>				
<b>1,2-Dichloroethane</b>				
<b>1,1-Dichloroethylene (vinylidene chloride)</b>				



Dichloromethane				
2-4 Dichlorophenol				
2,4-Dichlorophenoxy acetic acid (2,4-D)				
Diclofop-methyl				
Dimethoate				
Dinoseb				
Diquat				
Diuron				
Glyphosate				
Heptachlor + Heptachlor Epoxide				
Lindane (Total)				
Malathion				
Methoxychlor				
Metolachlor				
Metribuzin				
Monochlorobenzene				
Paraquat				
Parathion				
Pentachlorophenol				
Phorate				
Picloram				
Polychlorinated Biphenyls(PCB)				
Prometryne				
Simazine				
THM (NOTE: latest annual average)	<b>SEE NOTE</b>	<b>21.75</b>	<b>ug/L</b>	
Total Haloacetic Acids (HAA5) (NOTE: latest annual average)	<b>SEE NOTE</b>	<b>18.95</b>	<b>ug/L</b>	
Temephos				
Terbufos				
Tetrachloroethylene				
2,3,4,6-Tetrachlorophenol				
Triallate				
Trichloroethylene				
2,4,6-Trichlorophenol				
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)				
Trifluralin				
Vinyl Chloride				

**List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.**

Parameter	Result Value	Unit of Measure	Date of Sample



		<u>THM</u>	<u>HAA5</u>
<b>NOTE:</b>	<b>FEB 9</b>	- 11.0	13.1
	<b>MAY 11</b>	- 25.0	25.5
	<b>AUG 10</b>	- 26.0	18.4
	<b>NOV 9</b>	- 25.0	18.8
		<u>21.75</u>	<u>18.95</u>